

## **Deck Requirements/Inspection Sheet**

PERMIT #: \_\_\_\_\_\_ ADDRESS: \_\_\_\_\_

Note: Any revisions to an existing deck will require the entire deck to be in conformity with current codes.

- IF CONNECTION TO LEDGER CANNOT BE OBSERVED, DECK IS REQUIRED TO BE BUILT WITHOUT A LEDGER (self-supporting with lateral connection to building) R 507.8
- No attachment of ledgers through exterior veneers (brick, masonry, stone) DCA6 Fig. 17
- 3. Footings within 5 feet of building are required to be dug to depth of footing of house. **DCA6 Pg. 17**
- 4. Bolts shall have washers under the head and nuts. **R 507.5.2**
- 5. Rails must be blocked to deck joists. DCA6 Fig 25
- The use of sloped joist hangers is required when attaching stair stringers.
  DCA6 Fig. 31
- 7. Cantilevered joists require blocking over beam R507.6

## Required Inspections: Schedule with Bob Altman 215.646.5302 x

**313 - 24hr notice required** (if our inspector is unable to conduct his inspection due to contractor/applicant error or if more than (2) fails occur for the same inspection a \$50.00 reinspection fee is due prior to the scheduling of next inspection)

FOOTING INSPECTION	PASS FAIL
FRAMING & ZONING INSPECTION	PASS FAIL
FINAL	

NOTES: